

(CORRIGENDUM – 01)

Price Schedule

Annexure III (Revised)

Sl. no	Description of Item	Unit	Rate (In Rs.)	Amount (in Words.)
1.	Dismantling and removal of existing chiller unit.	One Job		
2.	Supply of water cooled chiller unit capacity 7.5 TR or more, packaged type comprising of refrigeration compressor, evaporator, condenser, pumps etc along with enunciator and starter, control panel etc (all parts should be of reputed brand). Chilled water at 6-12°C at 5 bar pressure @ 60 LPM for cooling of mould.	1 No.		
3.	Connection of existing cooling pipe line to Side machine & cooling tower, electrical connection, foundation etc of new chiller with necessary arrangement and fittings suit the existing system.	One Job		
4.	Commissioning of new chillers unit.	One Job		
5	Taxes (as applicable) IGST			
Total		Rs.		

